

वरिष्ठ कमाण्डेंट का कार्यालय
केन्द्रिय औद्योगिक सुरक्षा बल
(गृह मंत्रालय)

इकाई: वीएसटीपीएस विन्ध्यनगर
जिला: सिंगरौली मध्य प्रदेश

पत्र सं०केओसुब/वीएसटीपीएस/अग्नि/2021-1245

दिनांक 15/09/2021

TO WHOM IT MAY CONCERN

It is certified that De Paul School, Vindhyanagar, District- Singrauli (MP), located in township of NTPC Vindhyanagar has sufficient fire safety systems. Construction of the school building has been done as per BIS Code 14435:2013 and having sufficient means of escape in school building for the life safety of staff and students.

First-aid Fire fighting equipments (Portable fire extinguishers) are installed by the Fire Wing of CISF and monthly checking /testing is carried out as per guidelines of BIS-2190:2010 re-affirmed 2015. Elementary first-aid fire fighting training is also imparted to the school staff and students from time to time.



(एस वेंकट रेड्डी)

(S Venkata Reddy)

सहायक कमाण्डेंट/अग्नि

Asst. Commandant/Fire

केओसुब इकाई वीएसटीपीपी विन्ध्यनगर

CISF Unit VSTPP Vindhyanagar

ASST. COMMANDANT/FIRE

CISF Unit VSTPS Vindhyanagar

Distt. Singrauli (M.P.)